

10 N Livingston St, Suite 201 Madison, WI 53703


OneEnergy

PINE HILL SOLAR PINE HILL SOLAR WI, LLC PINE HIL ROSSES 43,008997, 28,045007

CONSTRUCTION **IMINARY** FOR NOT


	CK'D	WW				
	ВУ	SC				
	DATE	11.06.2025 JS				
REVISION LOG	REV DESCRIPTION	☐ A 30% CIVIL PLANS				
SH	r⊻ FFT	TIT	F.	_		
511						

C-200



- USE HARD, DURABLE, ANGULAR STONE OR RECYCLED CONCRETE MEETING THE GRADATION IN TABLE 1 OF WISC. DNR TECHNICAL STANDARD 1057. WHERE THIS GRADATION IS NOT AVAILABLE, MEET THE GRADATION IN WISC. DOT 2018 STANDARD SPC., SECT. 312, SELECT CRUSHED MATERIAL.
- 2. SLOPE THE STONE TRACKING PAD IN A MANNER TO DIRECT RUNOFF TO AN APPROVED TREATMENT PRACTICE.
- 3. SELECT FABRIC TYPE BASED ON SOIL CONDITIONS AND VEHICLE LOADING.
- INSTALL TRACKING PAD ACROSS FULL WIDTH OF THE ACCESS ROAD, OR RESTRICTING EXISTING TRAFFIC TO A DEDICAT EGRESS LANE AT LEAST 12 FEET WIDE ACROSS THE TOP OF THE PAD.
- IF A 50' PAD LENGTH IS NOT POSSIBLE DUE TO SITE GEOMETRY, INSTALL THE MAXIMUM LENGTH PRACTICABLE AND SUPPLEMENT WITH ADDITIONAL PRACTICES AS NEEDED.
- THE 2"-3" NOMINAL ROCK FROM CONSTRUCTION ENTRANCES ARE TO BE REMOVED AT THE END OF PROJECT CONSTRUCTION, AND ROAD DRESSED WITH CLASS V ROCK.


C-600-2 | ROCK CONSTRUCTION ENTRANCE



NOTES:

- 1. POST SPACING SHALL NOT EXCEED 6 FEET.
- POST TO BE ON LOWER SIDE OF SLOPE (TOWARD PROPERTY BOUNDARY OR POND SIDE) AND FENCE UPSTREAM.
- 4. TRENCH SHALL BE A MIN. OF 6 INCHES DEEP BY 6 INCHES WIDE. 5. MACHINE SLICED METHOD IS ACCEPTABLE

C-600-3 | SILT FENCE NOT TO SCALE




DETAIL FOR TYPES: WOOD CHIP, COMPOST OR ROCK BE USED ON HARD SURFACES. NO STAKES IF SHOWN ON HARD SURFACES

1. SPACE BETWEEN STAKES SHALL BE A MAXIMUM OF 5 FEET FOR DITCH CHECKS OR 15 FEET FOR OTHER APPLICATIONS.

- 2. PLACE STAKES AS NEEDED TO PREVENT MOVEMENT OF SEDIMENT CONTROL LOGS PLACED ON SLOPES OR AS NEEDED DUE TO OTHER FACTORS. STAKES SHALL BE INCIDENTAL.

C-600-4 | SEDIMENT CONTROL LOG



10 N Livingston St, Suite 201 Madison, WI 53703

One<u>Energy</u>

PINE HILL SOLAR WI, L


CONSTRUCTION

FOR

CIVIL DETAILS

C-600

₹




SECTION VIEW


NOTES: 1. SEE C-200 FOR AGGREGATE EXTENTS


C-600-5 | SKID-MOUNTED EQUIPMENT PAD NOT TO SCALE

SEDIMENT CONTROL LOGS USED FOR SILT FENCE RELIEF SEE DETAIL

C-600-1 | TYPICAL SOLAR ACCESS ROAD
NOT TO SCALE








- 1. SEDIMENT CONTROL LOGS USED FOR SILT FENCE RELIEF SHALL BE A MINIMUM OF $6^{\rm o}$ IN DIAMETER.
- OPENING IN SILT FENCE TO BE MINIMUM 3' AND SEDIMENT CONTROL LOGS TO OVERLAP SILT FENCE 1.5' ON EITHER SIDE.
- WOOD STAKES TO BE DRIVEN THROUGH BACK HALF OF SEDIMENT CONTROL LOGS AT 45° ANGLE WITH THE TOP OF THE STAKE POINTING UPSTREAM.

C-600-6 | SILT FENCE RELIEF



- SEED APPROPRIATE TEMPORARY SEED MIX PRIOR TO INSTALLING THE BLANKET.
- 2. ENSURE THE ENDS ARE PROPERLY SECURE.
- INSTALL STAPLES PER MANUFACTURER SPECIFICATION TO HOLD THE BLANKET IN PLACE.
- OVERLAP THE BLANKET 6" MINIMUM TO ENSURE WATER THAT FLOWS ON TOP OF THE BLANKET AND IS UNABLE TO FLOW UNDER THE BLANKET.

C-600-7 | EROSION CONTROL BLANKET

